



Addendum II

SUBJECT: Spill Response and Remediation (SRR)

SOLICITATION: RFP 2019-010a

DATE: July 15, 2019

A. RESPONSES TO QUESTIONS RECEIVED ARE AS FOLLOWS:

Q1: What size crew were you expecting per response (for a typical small transformer spill)?

A1: A typical small spill uses a two-man crew but with regulators and substation transformers and the size of the spill (gallons), it could easily take up to a six-man crew or larger.

****THIS ADDENDUM IS NOT REQUIRED TO BE RETURNED WITH THE BID PACKAGE****